

ALP UTILITIES FINISHED WATER ANALYSIS

<u>Description</u>	<u>Test Results</u>
pH	7.7 units
Color	<5 units
Alkalinity, Total	320 mg/L
Sulfate	16 mg/L
Chloride	57.6 mg/L
Nitrate	<0.01 mg/L
Mercury	<0.2 ug/L
Solids, Total Dissolved	389 mg/L
Aluminum	<0.028 mg/L
Antimony	0.144 mg/L
Barium	0.102 mg/L
Beryllium	<0.001 mg/L
Cadmium	<0.011 mg/L
Chromium	<0.012 mg/L
Nickel	<0.02 mg/L
Thallium	<0.017 mg/L
Zinc	<0.003 mg/L
Boron	<0.1 mg/L
Arsenic	<2.0 ug/L
Selenium	<3 ug/L
Silver	<0.2 ug/L
Calcium	74.0 mg/L
Magnesium	35.0 mg/L
Sodium	9.0 mg/L
Potassium	4.00 mg/L
Nitrite	<0.01 mg/L
Copper	0.08 mg/L
Iron	0.023 mg/L
Manganese	0.025 mg/L
Raw Fluoride	0.18 mg/L
Lead	0.00012 mg/
Average Hardness	26 grains per gallon
Average Chlorine Free	0.60 mg/L
Average Chlorine Total	1.0 mg/L